



MADC

Date: 23/05/2022

No. 2466/MIHAN/FIRE/2022

Renewal of Provisional Fire NOC

To,
The Principal ,
D.Y.Patil International School.
MIHAN Project Area,
Khapri (Rly),Nagpur,441108

Subject : Renewal of Provisional Fire No Objection Certificate.

- Reference:**
- 1) Provisional Fire NOC/MIHAN/FIRE/2771 dt.25.11.2009 – (Cancelled)
 - 2) Provisional Fire NOC No.2062/MIHAN/FIRE/2013 dt.15.05.2013.
 - 3) Application No. 01/FIRE/MADC/DYPIS/2017-18/05 dtd.14/06/2019 for renewal.
 - 4) Renewal of Provisional Fire NOC No.4239/MIHAN/FIRE/2019 dtd.11.07.19
 - 5) Letter dtd.10.07.2019 reg.undertaking fire freighting pipe line
 - 6) Application No.DYP/ADMIN/FIRE/2022-23/44 dtd.23.05.2022 for renewal of Provisional Fire NOC
 - 7) Application No.DYP/ADMIN/FIRE/2022-23/46 dtd.23.05.2022 for payment of demand note of Rs.2000/-

With reference to above subject that the Provisional fire No Objection Certificate No. MIHAN/FIRE/2771 dt.25.11.2009 was issued for D.Y. Patil Educational School at plot at Mouza Khapri(Rly) bearing Survey Nos.13 (part), 14(part), 17(part), 19(part), 23(part),25 (part),26(part),39(part),40(part),and16(part) Zudpi Jungle at Notified area of MIHAN for the construction and installation for Fire Fighting and fire safety arrangements of Building Block No.C –GF, J- G+1st floor ,L-Cafeteria, & R-G+2. The application received on dtd.08/05/2018 for renewal of building J only.(G+1)

On Dt.18.06.2019 the inspection carried out and found that the present Fire Fighting arrangement and fire safety arrangements are in working condition which was stated in Provisional Fire No Objection Certificate No.MADC MIHAN/FIRE/2771 Dt.25.11.2009 which was cancelled and amended Provisional fire No Objection Certificate No.2062/MIHAN/FIRE/2013 dt.15.05.2013. Therefore the renewal is hereby granted on following term & conditions.

Terms & conditions:-

- 1) The remaining building constructed should not be occupied without obtaining Completion/Final Fire No Objection Certificate.

Owner/Applicant should renew this certificate every year.

Storage of Inflammable material/Liquid in this building is not permitted.

Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B –Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur – 441 108

Tel: +91 –7104 –665665 ● Fax:+91-7104–665600 ● Email: jmd@madcindia.org

● Website: <https://madc.maharashtra.gov.in>



B. Chade
Manager

D.Y.Patil International School
Nagpur

[Signature]
Principal

D Y Patil International School
Nagpur

- 4) It shall be insured that all staff with security of the building are trained in handling firefighting equipment & installation.
- 5) All firefighting equipment & installation shall be well maintained and should be easy assessable.
- 6) MADC reserves right to amend/change conditions or impose new conditions considering the safety requirement of life an property.
- 7) The conditions of the certificate shall be binding not only to the applicant but also its successors and every persons deriving title through or under them.
- 8) After completion of remaining blocks the applicant/owner should apply for Provisional Fire No Objection Certificate from Fire Officer MADC Nagpur.
- 9) First Aid Fire Fighting & Mock drill should be conducted twice in a year and should inform MADC Fire Dept.
- 10) No Mobile tower is permitted without permission of MADC Ltd., Nagpur.
- 11) Every six month applicant/occupier will inform in return that all firefighting equipment & installation are in working condition.
- 12) During the inspection if the firefighting equipments & installations are not found working condition this certificate can be cancelled without preinformation.
- 13) Applicant to submit form B along with the application for renewal.
- 14) Vertical pipeline required change in 4 inch dia mtr. Instead on 1 inch dia.
- 15) Portable extinguishers 6 no. should be additional installed on G.F. & 1ST floor each.

Valid upto : 23.05.2023

[Signature]
23/05/2022
Dy. Chief Fire Officer
Fire & Emergency Services
MADC, Ltd. Nagpur

Copy to : 1) Chief Engineer, MADC, Nagpur for information please.
2) Manager (F&A), MADC, Nagpur for information please.



Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN: U45203MH2002SGC136979

Central Facility Building, B-Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Tel: +91 -7104 -665665 ● Fax: +91-7104-665600 ● Email: jmd@madcindia.org

● Website: <https://madc.maharashtra.gov.in>

[Signature]
Manager

D Y Patil International School
Nagpur

[Signature]
Principal

D Y Patil International School
Nagpur